

School Environmental Inspection Summary For 2007 - 2008

School Name: Dever Elementary School
Address: 325 Mt. Vernon Street, MA 02125
Date of inspection: 2/19/2008
Inspector(s): Michael DiLorenzo
Has Written IPM Program in Office: Y
Date of Last IPM Activity Logged: 2/19/2008
Number of areas: 41
Number of areas inspected: 37
Source of Drinking Water: Bottled Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	0	0.0%
Visible Mold Growth	0	0.0%
Overt Pest Sign	3	8.1%
Clutter	2	5.4%
Dust	0	0.0%
Cleaning needed	0	0.0%
Repairs needed	7	18.9%
Improper Chemical Storage	1	2.7%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm		641
CO level	0 - 9 ppm		0
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³		0.024
VOC level	150 – 300 ppb		0
Temperature	68 – 75 degrees		69.5

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	7
Total number of urinals	17
Number of non-functioning urinals	0
Total number of toilets	36
Number of non-functioning toilets	0
Number with bad stall doors	0
Number of toilets without toilet paper	33
Number of bathroom sinks	12
Number of broken sinks	0
Number of soap dispensers	7
Number of broken dispensers	0
Percent of bathrooms without adequate soap	0.0%
Percent of bathrooms without paper towels	0.0%

